

**Salem Keizer School District  
Schirle Elementary  
RADON TESTING SAMPLE REPORT**

On-site June 14-17, 2010  
Report June 22, 2010

	June 2010	May 2009	July 2001
B1	1.3		
B2	1.2		
B3	2.0		
B4	1.0		
B5	1.2		
B6	1.3	<0.3	3.4
B7	0.7		
C1	1.5		
C2	1.4		
C3	1.4		
C4	1.3		
C5	1.6		
C6	1.7		
E1	1.1		
E2	1.1		
E3	1.5		
E4	1.4		
E5	0.7		
E6	1.1		
LRC	1.4		
Music	0.9		
Library	1.1		
Gym	0.8		
Counselor	1.7		
Speech	1.4		
LRC Workroom	1.5		
Conference room	1.3		
Main office	1.7		
Principal's office	3.6		
J. Johnson's office	1.8		
Staff room	2.0		
PE office	1.7		
Custodial Office	1.0		
Latchkey Portable	<0.3		
Portable, North	<0.3		
Portable, South	<0.3		

**Radon Levels reported in picoCuries/Liter (pCi/L)  
EPA Action Level is 4.0 pCi/L**